

## ***NEC (2020) – National Electrical Code***

### **480.7 DC Disconnect Means**

**(A) Disconnecting Means.** A disconnecting means shall be provided for all ungrounded conductors derived from a stationary battery system with a voltage over 60 volts dc. A disconnecting means shall be readily accessible and located within sight of the battery system.

